



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 5024629
Permit #: 00753-2025UPG
Request Rec'd: 06/18/2025
Approval Date: 06/21/2025 DS
Permit Expires: 12/23/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Christian County Farmers Supply Company 1210 North Cheney P.O. Box 377 Taylorville, IL 62568 Christian County Contact: Nathan Rogers 217/652-2773	FACILITY - name and address where tanks are located: Fuel 24 1200 North Cheney Taylorville, IL 62568 Christian County Contact: Jamie Young 217/824-3833
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
3	Kerosene	8,000	Currently in use	Federal
4	Gasoline - Mid-grade	8,000	Currently in use	Federal
5	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

Summary of Work

Overfill Alarm System is no longer working, All tanks have Overfill drop Tubes installed with shut off valves set at 90%. Removing the Overfill Alarm system from the equipment listing as it is no needed for Overfill Protection.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Midwest Tank Testing, LLC
2008 Medical Center Dr
Monticello, IL 61856

Contact Person: Stephen T. Hall
Phone: 217/714-4305
Email: midwesttanktestingsth@aol.com
Contractor License # IL002461 Exp. 1/2/2026

Sincerely,



Daniel Starks