



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2041759
Permit #: 00765-2025REM
Request Rec'd: 06/23/2025
Approval Date: 06/23/2025 DS
Permit Expires: 12/23/2025

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Michele Alvarado 773/456-5280	FACILITY - name and address where tanks are located: Circle K #1387 901 Dixie Highway Beecher, IL 60401 Will County Contact: Todd Nurmi 815/933-3365
--	---

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
1	15,000	Gasoline - Regular	
2	10,000	Diesel Fuel	
3	8,000	Gasoline - Regular	
4	7,000	Gasoline - Premium	

Summary of Work

All product piping, (vent piping will remain), STP sumps, UDC sumps, overspill buckets, overfill drop tubes, islands will be removed. Tank locations will remain the same along with the islands and canopy. An upgrade application will be submitted to install New piping, STP sumps, UDC sumps, Overspill buckets, Overfill drop tubes, TLS 450 plus with tank probes and STP/UDC sensors...

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: Keith@Andersonpump.com Contractor License # IL002275 Exp. 6/10/2027

Sincerely,

Daniel Starks