



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2023033
Permit #: 00772-2025INS
Request Rec'd: 06/23/2025
Approval Date: 06/23/2025 DS
Permit Expires: 12/23/2025

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: CIMA Developers, LP 30W180 Butterfield Rd. Warrenville, IL 60555 Du Page County Contact: Dan Soltis 630/715-1341 | FACILITY - name and address where tanks are located: The Pride of Elmhurst 217 E. Butterfield Road Elmhurst, IL 60126 Du Page County Contact: Dave Olson 630/653-1700 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|--------------------|------------------|
| 9 | Gasoline - Regular | 20,000 | Tank Not Installed | Federal |
| 10 | Gasoline - Premium | 10,000 | Tank Not Installed | Federal |
| 11 | Diesel Fuel | 10,000 | Tank Not Installed | Federal |

Tank 9 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Fiberglass Non-Corrosive | New |
| Corrosion Protection - Tank | Composite Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Overfill Prevention Device | Overfill Alarm | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Extractor Fitting Valves | New |
| Piping | Fiberglass Double Wall Ameron Dualoy 3000/LCX | New |
| Piping | Flex Connector Steel | New |
| Piping | Other Steel Riser | New |
| Piping | Other Submersible Pump | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Composite Double Wall Modern Welding Glasteel II | New |

Tank 10 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Fiberglass Non-Corrosive | New |
| Corrosion Protection - Tank | Composite Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Overfill Prevention Device | Overfill Alarm | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Extractor Fitting Valves | New |
| Piping | Fiberglass Double Wall Ameron Dualoy 3000/LCX | New |
| Piping | Flex Connector Steel | New |
| Piping | Other Steel Riser | New |
| Piping | Other Submersible Pump | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Composite Double Wall Modern Welding Glasteel II | New |

Tank 11 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Fiberglass Non-Corrosive | New |
| Corrosion Protection - Tank | Composite Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Overfill Prevention Device | Overfill Alarm | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Extractor Fitting Valves | New |
| Piping | Fiberglass Double Wall Ameron Dualoy 3000/LCX | New |
| Piping | Flex Connector Steel | New |
| Piping | Other Steel Riser | New |
| Piping | Other Submersible Pump | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Composite Double Wall Modern Welding Glasteel II | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------|
| 1/2 | Replacing - 1/2 |
| 3/4 | Replacing - 3/4 |
| 5/6 | Replacing - 5/6 |
| 7/8 | Replacing - 7/8 |
| 9/10 | Replacing - 9/10 |
| 11/12 | Replacing - 11/12 |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 11/12 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions.

There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

We are install (3) new tanks. A 20k regular tank, 10kpremium/10k diesel split tank. We will be installing (6) new dispensr sumps, with associated product/vent piping. (2) canopies to be installed by others over the auto and diesel islands, per site plan.

Special Contingencies


NOTES: Vents must meet section 175.440 of our rules. Dispensers must be a full 10' from all buildings and property lines.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 630/484-7374
Email: KeenanA@AndersonPump.com
Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks

For Office Use Only

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Piping Sump Sensors Not Regulated |
| Leak Detection - Piping | Piping Sump Sensors Not Regulated in Single Wall UDC Sump | Removing |

Dispenser 11/12 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|--|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Piping Sump Sensors Not Regulated |
| Leak Detection - Piping | Piping Sump Sensors Not Regulated in Single Wall UDC Sump | Removing |