



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2019574
Permit #: 00776-2025UPG
Request Rec'd: 06/23/2025
Approval Date: 06/24/2025 DS
Permit Expires: 12/24/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: U.S. Citgo Oil, Inc. 520 Newport Ct. Island Lake, IL 60042 McHenry County Contact: Eddie Wood 312/662-3935	FACILITY - name and address where tanks are located: U.S. Citgo Oil, Inc. 520 W. Newport Circle Island Lake, IL 60042 Lake County Contact: Eddie Wood 312/662-3935
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	12,000	Currently in use	Federal
5	Gasoline - Mid-grade	12,000	Currently in use	Federal
6	Gasoline - Premium	12,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Flexible Double Wall A.P.T. Poly Tech	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech
Piping	Other Steel Riser	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Flexible Double Wall A.P.T. Poly Tech	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech
Piping	Other Steel Riser	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Flexible Double Wall A.P.T. Poly Tech	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech
Piping	Other Steel Riser	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispensers on the Permit

Dispenser	Action
1/2	Replacing - 1/2
3/4	Replacing - 3/4
5/6	Replacing - 5/6
7/8	Replacing - 7/8

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
🔧 Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work


We will be replacing the existing piping and sumps with all new ATP piping and new dispenser/tank top sumps. Islands to be hand formed and raised with steel bollards as collision protection. Canopy to remain the same.

Special Contingencies

NOTE: Dispensers must be a full 10' to all buildings and property lines.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 630/484-7374 Email: KeenanA@AndersonPump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks

For Office Use Only

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump	Removing

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump	Removing

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump	Removing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing