



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2044901  
Permit #: 00789-2025UPG  
Request Rec'd: 06/25/2025  
Approval Date: 06/25/2025 DS  
Permit Expires: 12/26/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Love's Travel Stops & Country Stores, Inc. 10601 N. Penn P.O. Box 26210 Oklahoma City, OK 73120 Contact: Kyle Collins 405/834-0311	<b>FACILITY</b> - name and address where tanks are located: Love's Travel Stop #292 12 W. Northbrook Drive Dwight, IL 60420 Livingston County Contact: Dustin Roberts 815/584-9545
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	20,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

Replacement of RUL spill bucket- drop tube is currently seized in the riser. Spill bucket to be removed along with drop tube. (please note- we are not doing anything with sump sensors- the system would not let me proceed without adding it.)

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Northern Indiana Mechanical 3311 East 15th avenue Gary, IN 46403	Contact Person: Madeline Kingery Phone: 219/963-1640 Email: nimco653@hotmail.com Contractor License # IL292 Exp. 5/9/2027

Sincerely,

Daniel Starks