



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2034486
Permit #: 00805-2025UPG
Request Rec'd: 06/03/2025
Approval Date: 06/27/2025 DS
Permit Expires: 12/29/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 7-Eleven, Inc. 3200 Hackberry Road - Gas Compliance Irving, TX 75063 (None) County Contact: Zachary Davis 937/203-7827	FACILITY - name and address where tanks are located: 7-Eleven # 34720 702 E. Tri-State Tollway, Lincoln North South Holland, IL 60473 Cook County Contact: Peggie Betz 972/828-7805
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
18	Gasoline - Regular	10,000	Currently in use	Federal
19	Gasoline - Regular	10,000	Currently in use	Federal
20	Diesel Fuel	10,000	Currently in use	Federal
21	Gasoline - Premium	10,000	Currently in use	Federal

Tank 18 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - North	New

Tank 19 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - North	New

Tank 20 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - West	New

Tank 21 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket - Northwest	New
Spill Containment Device	Double Wall Spill Bucket - West	Replacing - Spill Contain Device - Double Wall Spill Bucket

Summary of Work

Replacement of PUL spill containment and drop tube- drop tube is seized within the PUL single wall fuel drop spill containment- upgrading to a double wall. Also replacing a single wall vapor spill bucket- this vapor bucket is the vapor bucket for all of the tanks here. We have attached a picture of the tank pad- two tanks to the east, two tanks to the west and the vapor in the very middle.

Special Contingencies**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Northern Indiana Mechanical
3311 East 15th avenue
Gary, IN 46403

Contact Person: Madeline Kingery
Phone: 219/963-1640
Email: nimco653@hotmail.com
Contractor License # IL292 Exp. 5/9/2027

Sincerely,



Daniel Starks