



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2023098  
Permit #: 00806-2025UPG  
Request Rec'd: 06/29/2025  
Approval Date: 06/30/2025 DS  
Permit Expires: 12/30/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: M & Y Dolton Property, LLC 1421 E. Sibley Blvd. Dolton, IL 60419 Cook County Contact: Mohamed Ali 708/983-9620	<b>FACILITY</b> - name and address where tanks are located: Hala Dolton d/b/a Exxon 1421 E. Sibley Blvd. Dolton, IL 60419 Cook County Contact: Mohamed Ali 708/983-9620
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Other Submersible Pump	New
Piping	Shear Valves	New

**Dispensers on the Permit**

Dispenser	Action
9/10	Sump / Sensors Changing

**Dispenser 9/10 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing

**Summary of Work**

Replacing dispenser sump at disp 9/10 with new Bravo FG SW dispenser sump, repiping again, new shear valves, new flex hoses, existing sump sensor.  
Replacing Submersible on tank 1.

**Special Contingencies**

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

American Petroleum Solutions LLC  
2911 Lund avenue apt 8  
Rockford, IL 61109

Contact Person: Haibat Khan  
Phone: 909/312-9449  
Email: apetro.office@gmail.com  
Contractor License # IL002454 Exp. 5/21/2026

Sincerely,



---

Daniel Starks