



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2020306
Permit #: 00807-2025UPG
Request Rec'd: 06/30/2025
Approval Date: 06/30/2025 DS
Permit Expires: 07/11/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061 Lake County Contact: Raymond Kirchner 847/837-0777	FACILITY - name and address where tanks are located: Wauconda BP (GEI-161) 512 W. Liberty Street Wauconda, IL 60084 Lake County Contact: Brittany Custer 847/837-0777
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
8	E85	6,000	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New

Summary of Work

Repacing Stainless Steel balve and piping at E85 STP tank top sump.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 224/476-4367 Email: tk@perftank.com Contractor License # IL881 Exp. 12/8/2026

Sincerely,

Daniel Starks