



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 3027646  
Permit #: 00808-2025UPG  
Request Rec'd: 06/30/2025  
Approval Date: 06/30/2025 DS  
Permit Expires: 12/30/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: United Township High School 1275 Avenue of the Cities East Moline, IL 612444100 Rock Island County Contact: David Bisby 309/752-1682	<b>FACILITY</b> - name and address where tanks are located: United Twp. High School Dist. 30 1275 Avenue of the Cities East Moline, IL 612444100 Rock Island County Contact: Dave Bisby 309/752-1682
--	--

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Overfill Alarm
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Overfill Alarm
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Dispensers on the Permit**

Dispenser	Action
1/2	New
Reg/DSL	Removing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Dispenser Reg/DSL Equipment**

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

**Summary of Work**

Removal of existing product piping, spill buckets, dispenser, and ATG. Installation of new STP sumps, STPs, piping, UDC, island, ATG and spill buckets. Existing piping removed under Stenstrom Petroleum as licensed remover. Permit# 00738-2025REM

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Evora Energy LLC 4405 SE Beisser Drive Suite 108 Grimes, IA 501115312	Contact Person: Abby Sellers Phone: 309/945-3851 Email: jburton@evora-group.com Contractor License # IL002474 Exp. 5/28/2027

Sincerely,



Daniel Starks

**For Office Use Only****Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

**Dispenser Reg/DSL Equipment**

Equipment Type	Permit Equipment	Action
----------------	------------------	--------