

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3012501
Permit #: 00819-2025CAT
Request Rec'd: 07/01/2025
Approval Date:07/01/2025 DS
Permit Expires: 01/02/2026

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Bethany Enterprises, Inc. 101 Woodland Road Milan, IL 61264 Rock Island County

Contact: Bill Ernst 563/332-2408

FACILITY

- name and address where tanks are located:

QC Mart

1726 2nd Avenue Rapids City, IL 61278 Rock Island County

Contact: Sherry Crowe 563/332-2408

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 9 | Diesel Fuel | 5,000 | Currently in use | Federal |

Tank 9 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|----------------------------------|--------|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector | New |

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Adding a 5lbs anode to tank #9 STP metal componets. The sump contains water.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Janiel J. Starke

Pipeco, Inc. 610 29th Street Bettendorf, IA 52722 Contact Person: Robert Schafer

Phone: 563/344-0700 Email: rob@pipecoinc.com

Contractor License # IL2034 Exp. 9/28/2026

Sincerely,

Daniel Starks