

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

 FOR OFFICE USE ONLY

 Facility #:
 2019087

 Permit #:
 00837-2025UPG

 Request Rec'd:
 07/03/2025

 Approval Date:07/07/2025 DS
 Permit Expires:

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	FACILITY - name and address where tanks are located:
Winbeecher, LLC 28W165 Belleau P.O. Box 706 Winfield, IL 60190 Du Page County	Maria Petroleum, Inc. d/b/a Winfield & Beecher Shell 0S151 Winfield Road Winfield, IL 60190 Du Page County
Contact: Pete Mancini 630/456-4427	Contact: Prakash Kuruvilla 630/456-4427

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	10,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

removing old spill bucket due to seized drop tube. installing new OPW double wall spill bucket.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:		
Big Daddy Pump & Compliance 301 Main St Unit 105 Antioch, IL 60073	Contact Person: Billy Umphrey Phone: 352/901-4467 Email: billy@bigdaddypump.com Contractor License # IL002457 Exp. 12/2/2026	

Sincerely,

Janiel J. Starke

Daniel Starks