



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 5042054
Permit #: 00838-2025UPG
Request Rec'd: 07/03/2025
Approval Date: 07/07/2025 DS
Permit Expires: 01/07/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231 | FACILITY - name and address where tanks are located: Casey's General Store #2457 1204 North Main Street Chatham, IL 62629 Sangamon County Contact: Jill Reams-Widder 515/965-6238 |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 2 | Diesel Fuel | 12,000 | Currently in use | Federal |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------------|
| 5/6 | Sump / Sensors Changing |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---------------------------------------------------------------|--------|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall UDC Sump | New |

Summary of Work

Installed a positive shutdown sensor in UDC 5/6.

Special Contingencies

| | |
|--------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108 | Contact Person: Robert Stenstrom Phone: 414/491-1002 Email: mikem@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026 |

Sincerely,

Daniel Starks