

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2042386
Permit #: 00839-2025UPG
Request Rec'd: 07/03/2025
Approval Date:07/07/2025 DS
Permit Expires: 01/07/2026

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909

Knox County

Contact: Joey Cupp 865/588-7488

FACILITY

- name and address where tanks are located:

Pilot Travel Center #473 23841 West Eames Street Channahon, IL 60410

Will County

Contact: Ben Cooper 865/588-7488

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 3 | Gasoline - Premium | 8,000 | Currently in use | Federal |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|--------|
| Piping | Ball Valves | New |
| Piping | Flex Connector Steel | New |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|--------|
| Piping | Ball Valves | New |
| Piping | Flex Connector Steel | New |

Summary of Work

Replacment of ball valve and flex line in the RUL STP Sump and the PUL STP sump.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Northern Indiana Mechanical 3311 East 15th avenue

Gary, IN 46403

Contact Person: Madeline Kingery

Phone: 219/963-1640

Email: nimco653@hotmail.com

Contractor License # IL292 Exp. 5/9/2027

Sincerely, Daniel J. Stark

Daniel Starks