



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 6026067
Permit #: 00854-2025CAT
Request Rec'd: 07/08/2025
Approval Date: 07/08/2025 DS
Permit Expires: 01/08/2026

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: QuikTrip Corporation 4705 South 129th East Ave. Tulsa, OK 74134 Contact: QuikTrip Corporation 918/615-7304	FACILITY - name and address where tanks are located: Quik Trip # 698 2809 Godfrey Road Godfrey, IL 62035 Madison County Contact: Laura Thompson 918/615-7658
---	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Gasoline - Regular	12,000	Currently in use	Federal
3	Gasoline - Premium	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Transition sump	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - Transition sump

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Transition sump	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - Transition sump

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Transition sump	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - Transition sump

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work


CP wire repair for the anode leads damaged by concrete construction. Also, Three 5-pound high potential magnesium anodes to be installed on the piping in the manway S of dispensers 7/8

PERSON, FIRM OR COMPANY PERFORMING WORK:

Tanknology
880 Church Road
Elgin, IL 60123

Contact Person: Linda Przydzial
Phone: 512/380-7117
Email: dhollander@tanknology.com
Contractor License # IL2089 Exp. 3/4/2026

Sincerely,



Daniel Starks