



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 3040332 |
| Permit #: | 00867-2025UPG |
| Request Rec'd: | 07/09/2025 |
| Approval Date: | 07/09/2025 DS |
| Permit Expires: | 01/09/2026 |

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.



THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Martin & Bayley, Inc. P.O. Box 385 Carmi, IL 62821 White County Contact: Landon Bayley 618/382-2334Ext.248 | FACILITY - name and address where tanks are located: Huck's #358 1415 W Alta Road Peoria, IL 61615 Peoria County Contact: Kenny Haun 618/382-2334 |
|--|--|


Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 20,000 | Currently in use | Federal |
| 2 | Gasoline - Premium | 10,000 | Currently in use | Federal |
| 3 | Diesel Fuel | 4,000 | Currently in use | Federal |
| 4 | Kerosene | 4,000 | Currently in use | Federal |


Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|---|---|---|
| Corrosion Protection - Piping | Flexible Non-Corrosive | Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive |
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector | Removing |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection - East | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection - East |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection - West | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection - West |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |
| Piping | Ball Valves | New |
| Piping | Extractor Fitting Valves | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Flexible Double Wall Total Containment Enviroflex non-corrosive |
| Piping | Other Steel Riser | New |
| Piping | Polyethylene Chase | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump - East | Replacing - Piping - Single Wall STP/Tanktop Sump - East |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall STP/Tanktop Sump - West | Replacing - Piping - Single Wall STP/Tanktop Sump - West |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |


Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|---|---|---|
| Corrosion Protection - Piping | Flexible Non-Corrosive | Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive |
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector - STP | Removing |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |
| Piping | Ball Valves | New |
| Piping | Extractor Fitting Valves | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Flexible Double Wall Total Containment Enviroflex non-corrosive |
| Piping | Other Steel Riser | New |
| Piping | Polyethylene Chase | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|---|---|---|
| Corrosion Protection - Piping | Flexible Non-Corrosive | Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive |
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector - STP | Removing |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |
| Piping | Ball Valves | New |
| Piping | Extractor Fitting Valves | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Flexible Double Wall Total Containment Enviroflex non-corrosive |
| Piping | Other Steel Riser | New |
| Piping | Polyethylene Chase | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |


Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|---|---|---|
| Corrosion Protection - Piping | Flexible Non-Corrosive | Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive |
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector - STP | Removing |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |
| Piping | Ball Valves | New |
| Piping | Extractor Fitting Valves | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Flexible Double Wall Total Containment Enviroflex non-corrosive |
| Piping | Other Steel Riser | New |
| Piping | Polyethylene Chase | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |


Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------------|
| 1/2 | Sump / Sensors Changing |
| 3/4 | Sump / Sensors Changing |
| 5/6 | Sump / Sensors Changing |
| 7/8 | Sump / Sensors Changing |
| 9/10 | Sump / Sensors Changing |
| 11/12 | Sump / Sensors Changing |
| 13/14 | Sump / Sensors Changing |
| 15/16 | Sump / Sensors Changing |
| 17/18 | Replacing - 17/18 |
| 19/20 | Sump / Sensors Changing |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|---|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|---|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 11/12 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 13/14 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 15/16 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 17/18 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 19/20 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Summary of Work

We will be removing all underground piping, risers, spill buckets, UDC's, islands, tank top STP sumps, and tank top equipment. The dispensers will be set aside for reuse. We will be installing new OPW doublewall pipe, new OPW spill buckets, probes, new 450 TLS plus with csld, new STP sumps, new risers, and new UDC's.

Special Contingencies

NOTES: Site is being re-piped from existing tanks to the same dispenser locations. Dispensers MUST be a full 10' from buildings and property lines.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Bryan Estes
Phone: 309/678-8061
Email: pcarrabbia@iome.com
Contractor License # IL1293 Exp. 2/4/2026

Sincerely,



Daniel Starks

For Office Use Only**Tank 1 Equipment**

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump East | Removing |
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump West | Removing |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump | Removing |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump | Removing |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump | Removing |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 11/12 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 13/14 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 15/16 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 17/18 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |

Dispenser 19/20 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |