



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 4-012377  
Permit # 01808-2006FLX  
Request Rec'd 11/28/2006  
Amended Date  
Approval Date 11/30/2006 JC  
Permit Expires 5/30/2007

**Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|                                                                                                                                                                                                                      |                                                                                                                                                                                                 |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:<br>Colonial Pantry, LTD<br>716 South Randolph Street, P.O. Box 1004<br>Champaign, IL 61820<br>Contact: Patrick Miller (217) 352-6789 | <b>(2) FACILITY</b> - name and address where tanks are located:<br>Colonial Pantry #10<br>S.E. Corner I-74 & Collison Road<br>Oakwood, Vermilion Co., IL<br>Contact: John Miller (217) 352-6789 |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:**

- (a) Number and size of tanks being upgraded or repaired:** (TK # 6, 7) - 10,000 gallons, (TK # 8) - 14,000 gallons, (TK # 9) - 4,000 gallons
- (b) Type of flex connector(s):** (TK # 6, 7, 8, 9) - Existing steel flex connectors
- (c) Product stored in each tank:** (TK # 6, 7) - Diesel Fuel, (TK # 8, 9) - Gasoline
- (d) Corrosion Protection being installed with flex connector(s):** (TK # 6, 7, 8, 9) - (Installing) Sacrificial anodes cathodic protection (TK # 6, 7, 8, 9) - Anodes will be installed at submersible sumps only.

- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

|                                                                                                        |                                                                |
|--------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|
| <b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b><br>Midwest Petroleum Service<br>Danville, IL 61834 | Contact Person:<br>Phone:<br>Contractor Registration #    Exp. |
|--------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)