



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2012592
Permit #: 00750-2025UPG
Request Rec'd: 06/18/2025
Approval Date: 06/18/2025 DS
Amended Date: 07/14/2025 DS
Permit Expires: 12/18/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Zion Travel Center, Inc. 702 Kentshire Circle Elgin, IL 60124 (None) County Contact: Japneet Khaira 765/881-0511	FACILITY - name and address where tanks are located: Toor's Car & Truck Plaza 43067 N. Hwy. 41 I-94 & Russell Rd. Wadsworth, IL 60083 Lake County Contact: Sam Toor 847/395-5000
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Gasoline - Regular	12,000	Currently in use	Federal
12	Diesel Fuel	20,000	Currently in use	Federal

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Diesel Tank# 12 : Install new fill riser, replace overspill bucket and overfill drop tube. AMEND TO INCLUDE REGULAR TANK# 9: Install new Fill riser. Replace Overspill bucket and Overfill drop tube.

Special Contingencies

Amendment Reason:

Overspill bucket on Regular Tank# 9 was found to be in very bad condition. Installing new Fill riser. Replacing Overspill bucket and overfill drop tube.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 708/560-5590
Email: Keith@Andersonpump.com
Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



Daniel Starks