



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2006925
Permit #: 00908-2025UPG
Request Rec'd: 07/15/2025
Approval Date: 07/15/2025 DS
Permit Expires: 01/15/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Zainab, Inc. 17951 S. Halsted Street Homewood, IL 60430 (None) County Contact: Waseem Ahmed 708/590-4099	FACILITY - name and address where tanks are located: Zainab, Inc. 17945 S. Halsted Street Homewood, IL 60430 Cook County Contact: Waseem Ahmed 708/590-4099
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Premium	6,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Summary of Work

The fusible link is damaged in dispenser 11-12. So we will be replacing the shear valve. There is a small leak underneath pump 3-4 inside a containment. Addressing both the issues as per OSFM inspection.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2027

Sincerely,

Daniel Starks