



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3006965
Permit #: 00913-2025UPG
Request Rec'd: 07/17/2025
Approval Date: 07/17/2025 DS
Permit Expires: 01/20/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Arthur J. Johnson Family Limited Partnership 1305 12th Avenue Rock Falls, IL 61071 (None) County Contact: Kathy Peugh 815/625-6380	FACILITY - name and address where tanks are located: 30th Street Shell 3002 18th Avenue Rock Island, IL 61201 Rock Island County Contact: David Behrens 815/625-6380
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Mid-grade	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Incon TS 750 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik Jr.

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Incon TS 750 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik Jr.

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Incon TS 750 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik Jr.

Summary of Work

Existing AutoStik JR to be replaced with an Incon TS-750 console and probes. Existing overfill alarm console to remain untouched, it is compatible with the new ATG.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Illowa Enterprises, Inc.
2703 4th Avenue
Moline, IL 61265

Contact Person: James Saddoris
Phone: 309/762-1729
Email: illowa@illowaent.com
Contractor License # IL981 Exp. 5/1/2026

Sincerely,



Daniel Starks