



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 6034678
Permit #: 00920-2025UPG
Request Rec'd: 07/17/2025
Approval Date: 07/17/2025 DS
Permit Expires: 01/20/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231 | FACILITY - name and address where tanks are located: Casey's General Store #1871 908 E. Noleman St. Centralia, IL 62801 Marion County Contact: Jill Reams-Widder 515/965-6238 |
|--|--|

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 2 | B-11 | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|--------|
| Piping | Flex Connector Steel | New |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|--------|
| Piping | Flex Connector Steel | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-----------------|
| 1/2 | Replacing - 1/2 |
| 3/4 | Replacing - 3/4 |
| 5/6 | Replacing - 5/6 |
| 7/8 | Replacing - 7/8 |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|------------------|
| Dispenser | Single Wall UDC Sump | Reusing Existing |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|------------------|
| Dispenser | Single Wall UDC Sump | Reusing Existing |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|------------------|
| Dispenser | Single Wall UDC Sump | Reusing Existing |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|------------------|
| Dispenser | Single Wall UDC Sump | Reusing Existing |

Summary of Work


Replace all 4 dispensers with new Wayne Ovations.

Breakout and replace island 1/2 to meet ADA height standards. Lower existing product piping in the existing UDC by replacing the flex connectors.

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|--|
| Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108 | Contact Person: Robert Stenstrom Phone: 414/491-1002 Email: mikem@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026 |

Sincerely,



Daniel Starks