



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2008958  
Permit #: 00935-2025CAT  
Request Rec'd: 07/18/2025  
Approval Date: 07/21/2025 DS  
Permit Expires: 01/21/2026

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County Contact: Zachery Davis 937/203-7827	<b>FACILITY</b> - name and address where tanks are located: Speedway #7032 432 E. Corning Avenue Peotone, IL 60468 Will County Contact: Mark Cullen 937/863-6513
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Gasoline - Regular	12,000	Currently in use	Federal
8	Gasoline - Regular	10,000	Currently in use	Federal
9	Gasoline - Premium	8,000	Currently in use	Federal
10	Diesel Fuel	6,000	Currently in use	Federal
11	Kerosene	4,000	Currently in use	Federal

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

**Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

**Tank 10 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

**Tank 11 Equipment**


Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp.	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp.

**NACE Certified Designer****NACE Certified Designer Number****Method of Integrity Assessment of Tanks****Special Contingencies****Summary of Work**

Adding one 1MgDR1 magnesium anode to each flex connector in the submersible pump containment sumps.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Berkeley Springs Instruments LLC 1 Quantum Circle Frostburg, MD 21532	Contact Person: Tina Lewis Phone: 262/720-6888 Email: james.davis@bsisentry.com Contractor License # IL002467 Exp. 8/20/2026

Sincerely,



Daniel Starks