

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2038987
Permit #: 00938-2025UPG
Request Rec'd: 07/18/2025
Approval Date:07/21/2025 DS
Permit Expires: 01/21/2026

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

7-Eleven, Inc.

3200 Hackberry Road - Gas Compliance

Irving, TX 75063 (None) County

Contact: Zachary Davis 937/203-7827

**FACILITY** 

- name and address where tanks are located:

7-Eleven #32866 4500 Algonquin Road Lake in the Hills, IL 60102 McHenry County

Contact: MANI SINGH 847/515-1498

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	10,000	Currently in use	Federal

## **Tank 2 Equipment**

Equipment Type	Permit Equipment	Action	
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve	
Piping	Other Fiberglass Riser	New	
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket	

### **Summary of Work**

Premium Tank# 2: Install a new Fill riser, Replace overspill bucket and overfill drop tube.

#### **Special Contingencies**

Janiel y. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 708/560-5590
Email: Keith@Andersonpump.com
Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel Starks