



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 1029430  
Permit #: 00946-2025CAT  
Request Rec'd: 07/21/2025  
Approval Date: 07/22/2025 DS  
Permit Expires: 01/22/2026

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Brake Time IL Properties, LLC 6300 Richmond Avenue, Suite 300 Houston, TX 77057 (None) County Contact: Omair Bashir 832/539-8190	<b>FACILITY</b> - name and address where tanks are located: Brake Time 125 S. Bloomington Road Grand Ridge, IL 61325 LaSalle County Contact: Muhammad Akhtar 832/539-8190
--	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	6,000	Currently in use	Federal
4	B-11	12,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	New

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - DSL Disp	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - DSL Disp

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

Testing Company Failed Cathodic Protection on 3/31/25, we are replacing depleted anodes on UDC 9/10 Flex's with 2- 5 lb anodes. Adding CP to Tank #3 STP Flex due to the presence of water and not being protected properly.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Midwest Tank Testing, LLC 2008 Medical Center Dr Monticello, IL 61856	Contact Person: Stephen T. Hall Phone: 217/714-4305 Email: midwesttanktestingsth@aol.com Contractor License # IL002461 Exp. 1/2/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks