



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022839
Permit #: 00952-2025UPG
Request Rec'd: 07/23/2025
Approval Date: 07/23/2025 DS
Permit Expires: 01/23/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Infant Jesus Oil Corporation 17460 Kedzie Avenue Hazel Crest, IL 60429 Cook County Contact: Luke Abraham 708/335-1852 | FACILITY - name and address where tanks are located: Atlas Indiana 803 17460 S. Kedzie Avenue Hazel Crest, IL 60429 Cook County Contact: William R. Shaver, Jr. 708/335-1852 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|----------------------|----------|------------------|------------------|
| 6 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 7 | Gasoline - Mid-grade | 12,000 | Currently in use | Federal |
| 8 | Gasoline - Premium | 12,000 | Currently in use | Federal |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |

Summary of Work

Replacing wireless line leak detection with mechanical line leak detection for 3 tanks.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: dj.white@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Daniel Starks