



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 1-007421
 Permit # 01052-2012INS
 Request Rec'd 10/04/2012
 Amended Date
 Approval Date 10/4/2012 JC
 Permit Expires 4/4/2013

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: AZ Green, LLC 4962 20th Street Rockford, IL 61109 Contact: Anjun Abdul (815) 873-0505</p>	<p>(2) FACILITY - name and address where tanks are located: AZ Green, LLC 4962 South 20th Street Rockford, Winnebago Co., IL Contact: Karen Havens (815) 847-9014</p>
--	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:** (TK # 4) - 12,000 gallons, (TK # 5) - 8,000 gallons
- (b) Type of tanks:** (TK # 4, 5) - (Installing) Fiberglass Double Wall XERXES
- (c) Type of piping:** (TK # 4, 5) - (Installing) partial (approximately just short of a total of 100') Fiberglass Double Wall Ameron Dualoy 3000/LCX from the submersible sumps to the new transition sump to accommodate / connect the existing piping from the old tank system to the new tank system (the existing piping is from the new transition sump to the existing dispensers), (TK # 4, 5) - (Installing) Transition Sump FRP fiberglass to accommodate the connection of new piping coming from the new tank submersibles to the existing piping going to the dispensers, (TK # 4, 5) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/L vent piping.
- (d) Product to be stored in each tank:** (TK # 4, 5) - Gasoline
- (e) Type of leak detection being used:**
 - Tank:** (TK # 4, 5) - (Installing) Automatic Tank Gauging Veeder Root TLS 450 with CSLD probes (the console is existing and will be used for this new tank system. The probes from the removed tanks will be installed in these new tanks), (TK # 4, 5) - (Installing) Interstitial Monitoring Veeder Root TLS 450
 - Piping:** (TK # 4, 5) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 450 (these are used line leak detectors from the old tank system and will be installed for use in this new piping system for these two new tank systems), (TK # 4, 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 at each submersible sump, at the new transition sump, and at the existing dispenser sumps.
- (f) Corrosion Protection being used:**
 - Tank:** (TK # 4, 5) - (Installing) Fiberglass Non-Corrosive
 - Piping:** (TK # 4, 5) - (Installing) Fiberglass Non-Corrosive
- (g) Spill containment devices, piping and dispenser containment devices:** (TK # 4, 5) - (Installing) Manhole Pre-manufactured OPW 1C-2100C-DEVR
- (h) Overfill prevention devices:**

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS: There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES:

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Nate Meyer Phone: (815) 398-6250 Contractor Registration # IL-1890 Exp. 03/07/2014</p>

Sincerely,

A handwritten signature in cursive script, reading "James J. Coffey", is positioned above a solid horizontal line that extends to the right.

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)