



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3044472
Permit #: 00966-2025UPG
Request Rec'd: 07/28/2025
Approval Date: 07/28/2025 SB
Permit Expires: 01/28/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Gold Star FS, Inc. 13125 IL Hwy 81 Cambridge, IL 61238 Henry County Contact: Ethan Washburn 815/499-9766	FACILITY - name and address where tanks are located: Gold Star FS, Inc. 2004 State Highway Aledo, IL 61231 Mercer County Contact: Adam Geertz 309/937-3369
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Dyed Diesel	30,000	Currently in use	Federal
6	Diesel Fuel	20,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing the existing damaged spills with new EBW Defender 5 gallon spills and installing new standard drop tubes.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: 563/344-0700 Email: rob@pipecoinc.com Contractor License # IL2034 Exp. 9/28/2026

Sincerely,

Shelly Bradley

Shelly Bradley