



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 4024502  
Permit #: 00967-2025UPG  
Request Rec'd: 07/25/2025  
Approval Date: 07/28/2025 SB  
Permit Expires: 01/28/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |  |
|--|--|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Casey's Retail Company<br>3305 SE Delaware Ave. P.O. Box 3004<br>Ankeny, IA 50021<br>Contact: Lee Lytle 515/446-6231 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Casey's General Store #1492<br>500 Central<br>Thomasboro, IL 61878<br>Champaign County<br>Contact: Karen R. 213/643-9920 |
|--|--|

**Tanks on the Permit For Piping Only**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1      | Diesel Fuel        | 6,000    | Currently in use | Federal          |
| 2      | Gasoline - Regular | 10,000   | Currently in use | Federal          |

**Tank 1 Equipment**

| Equipment Type | Permit Equipment     | Action |
|----------------|----------------------|--------|
| Piping         | Flex Connector Steel | New    |

**Tank 2 Equipment**

| Equipment Type | Permit Equipment     | Action |
|----------------|----------------------|--------|
| Piping         | Flex Connector Steel | New    |

**Dispensers on the Permit**

| Dispenser | Action          |
|-----------|-----------------|
| 1/2       | Replacing - 1/2 |
| 3/4       | Replacing - 3/4 |

**Dispenser 1/2 Equipment**

| Equipment Type | Permit Equipment     | Action           |
|----------------|----------------------|------------------|
| Dispenser      | Single Wall UDC Sump | Reusing Existing |

**Dispenser 3/4 Equipment**

| Equipment Type | Permit Equipment     | Action           |
|----------------|----------------------|------------------|
| Dispenser      | Single Wall UDC Sump | Reusing Existing |

**Summary of Work**

Breakout island 1/2 and install a new island. Reuse existing UDC, lower existing product piping by installing new flex connectors, and replace both fueling dispensers with new Wayne Ovation dispensers.

**Special Contingencies****PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Contact Person: Robert Stenstrom  
Phone: 414/491-1002  
Email: mikem@rstenstrom.com  
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

A handwritten signature in dark ink that reads "Shelly Bradley". The script is cursive and fluid, with the first name "Shelly" and last name "Bradley" clearly legible.

Shelly Bradley