



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2016651
Permit #: 00981-2025UPG
Request Rec'd: 07/29/2025
Approval Date: 07/30/2025 SB
Permit Expires: 01/30/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Thomas Leach, Sr. 255 S. West Avenue #5 Elmhurst, IL 60126 Du Page County Contact: Tom Leach Sr. 708/834-0481 | FACILITY - name and address where tanks are located: Gas Stop 575 South York Road Elmhurst, IL 60126 Du Page County Contact: Guadalupe Sabri 630/834-1700 |
|---|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2 | Gasoline - Regular | 8,000 | Currently in use | Federal |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|---------------------------------|--|
| Piping | Other Steel Riser | New |
| Spill Containment Device | Double Wall Spill Bucket - East | Replacing - Spill Contain Device - Single Wall Spill Bucket - East |

Summary of Work

Replacing Regular 2 Tank single wall spill bucket with new double wall spill bucket and riser.

Special Contingencies

| | |
|--|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Cardinal Compliance LLC 415 W. Golf Rd. Unit 28M-N Arlington Heights, IL 60005 | Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2027 |

Sincerely,

Shelly Bradley