



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2030034
Permit #: 01014-2025UPG
Request Rec'd: 04/24/2025
Approval Date: 08/05/2025 SK
Permit Expires: 02/05/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Tom Warren Oil Company 4243 South Knox Avenue Chicago, IL 60632 Cook County Contact: Anthony Antonaitis 773/735-6900	FACILITY - name and address where tanks are located: Warren Oil Co. 4242 S. Knox Avenue Chicago, IL 60632 Cook County Contact: Tony Antonaitis 773/838-3591
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
2	Used Oil	1,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350	Replacing - Leak Detect - Tank - Automatic Tank Gauging Omntec OEL 8000 II

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350	Replacing - Leak Detect - Tank - Automatic Tank Gauging Omntec OEL 8000 II

Summary of Work

Replacing existing Omntec 8000 ATG with Veeder Root TLS 350 along with Veeder Root In-tank probes.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154	Contact Person: Patrick Ferriter Phone: 708/917-2263 Email: patrick.ferriter@beaconssi.com Contractor License # IL002336 Exp. 1/27/2027

Sincerely,

Sean Keane