



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 3027646
Permit #: 00808-2025UPG
Request Rec'd: 06/30/2025
Approval Date: 06/30/2025 DS
Amended Date: 08/06/2025 DS
Permit Expires: 12/30/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: United Township High School 1275 Avenue of the Cities East Moline, IL 612444100 Rock Island County Contact: David Bisby 309/752-1682	FACILITY - name and address where tanks are located: United Twp. High School Dist. 30 1275 Avenue of the Cities East Moline, IL 612444100 Rock Island County Contact: Dave Bisby 309/752-1682
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Overfill Alarm
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Overfill Alarm
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Dispensers on the Permit

Dispenser	Action
1/2	New
Reg/DSL	Removing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser Reg/DSL Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Summary of Work

Removal of existing product piping, spill buckets, dispenser, and TS-750 ATG. Installation of new STP sumps, STPs, piping, UDC, island, Veeder Root TLS4B ATG and spill buckets. Existing piping removed under Stenstrom Petroleum as licensed remover. Permit# 00738-2025REM

Special Contingencies**Amendment Reason:**


Replace of TS-750 tank gauge with Veeder Root TLS4B automatic tank gauge.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Evora Energy LLC
4405 SE Beisser Drive Suite 108
Grimes, IA 501115312

Contact Person: Abby Sellers
Phone: 309/945-3851
Email: jburton@evora-group.com
Contractor License # IL002474 Exp. 5/28/2027

Sincerely,



Daniel Starks

For Office Use Only**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

Dispenser Reg/DSL Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------