



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Revised/Amended

FOR OFFICE USE ONLY
Facility #: 3027646
Permit #: 00808-2025UPG
Request Rec'd: 06/30/2025
Approval Date: 06/30/2025 DS
Amended Date: 08/06/2025 DS
Revision Date: 08/06/2025 DS
Permit Expires: 12/30/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: United Township High School 1275 Avenue of the Cities East Moline, IL 612444100 Rock Island County Contact: David Bisby 309/752-1682 | FACILITY - name and address where tanks are located: United Twp. High School Dist. 30 1275 Avenue of the Cities East Moline, IL 612444100 Rock Island County Contact: Dave Bisby 309/752-1682 |
|--|--|

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 4B | Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 750 |
| Overfill Prevention Device | Overfill Alarm | Replacing - Overfill Prev Device - Overfill Alarm |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Fiberglass Single Wall Piping |
| Piping | Single Wall STP/Tanktop Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 4B | Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 750 |
| Overfill Prevention Device | Overfill Alarm | Replacing - Overfill Prev Device - Overfill Alarm |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Fiberglass Single Wall Piping |
| Piping | Single Wall STP/Tanktop Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Dispensers on the Permit

| Dispenser | Action |
|-----------|----------|
| 1/2 | New |
| Reg/DSL | Removing |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser Reg/DSL Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
|----------------|------------------|--------|

Summary of Work

Removal of existing product piping, spill buckets, dispenser, and TS-750 ATG. Installation of new STP sumps, STPs, piping, UDC, island, Veeder Root TLS4B ATG and spill buckets. Existing piping removed under Stenstrom Petroleum as licensed remover. Permit# 00738-2025REM

Special Contingencies**Amendment Reason:**

Replace of TS-750 tank gauge with Veeder Root TLS4B automatic tank gauge.

Amendment Reason:

Replace of TS-750 tank gauge with Veeder Root TLS4B automatic tank gauge.

Revision Reason:

Added tank leak detection

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|---|---|
| Evora Energy LLC 4405 SE Beisser Drive Suite 108 Grimes, IA 501115312 | Contact Person: Abby Sellers Phone: 309/945-3851 Email: jburton@evora-group.com Contractor License # IL002474 Exp. 5/28/2027 |

Sincerely,



Daniel Starks

For Office Use Only**Tank 1 Equipment**

| Equipment Type | Permit Equipment | Action |
|----------------|--------------------------------|----------|
| Piping | Not Installed STP/Tanktop Sump | Removing |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|--------------------------------|----------|
| Piping | Not Installed STP/Tanktop Sump | Removing |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
|----------------|------------------|--------|

Dispenser Reg/DSL Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
|----------------|------------------|--------|