



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2042102
Permit #: 01021-2025UPG
Request Rec'd: 08/06/2025
Approval Date: 08/06/2025 DS
Permit Expires: 02/06/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: ARY Oak Lawn, LLC 1036 S. Ahrens Ave. Lombard, IL 60148 Du Page County Contact: Azra Khaja 773/691-7999 | FACILITY - name and address where tanks are located: ARY Oak Lawn, LLC 10718 South Cicero Avenue Oak Lawn, IL 60453 Cook County Contact: Aysar Abushanab 773/691-7999 |
|---|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 12,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
| Piping | Shear Valves | New |

Summary of Work

REPLACING LEAKING REGULAR 87 SHEAR VALVE UNDER DISPENSER 7/8.

Special Contingencies

NOTE: UDC must be installed if not already existing

| | |
|--|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Cardinal Compliance LLC 415 W. Golf Rd. Unit 28M-N Arlington Heights, IL 60005 | Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2027 |

Sincerely,

Daniel Starks