

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2009089
Permit #: 01031-2025UPG
Request Rec'd: 08/07/2025
Approval Date:08/07/2025 DS
Permit Expires: 02/09/2026

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Casey's Retail Company

3305 SE Delaware Ave. P.O. Box 3004

Ankeny, IA 50021

Contact: Lee Lytle 515/446-6231

**FACILITY** 

- name and address where tanks are located:

Bucky's Express #6502 8 E. Higgins Road Elk Grove Village, IL 60007 Cook County

Contact: Jill Reams-Widder 515/446-6238

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
13	Gasoline - Premium	15,000	Currently in use	Federal

## Tank 13 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

### **Summary of Work**

PUL drop tube seized. Replacing spill bucket and drop tube. Upgrading from SW to DW spill.

#### **Special Contingencies**

Janiel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 815/520-5292
Email: trevorh@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks