



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Extended

FOR OFFICE USE ONLY
Facility #: 2045957
Permit #: 00181-2025INS
Request Rec'd: 02/18/2025
Approval Date: 02/18/2025 DS
Extension Date: 08/11/2025
Permit Expires: 02/19/2026

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

| OWNER OF TANKS | FACILITY |
|--|---|
| - Corporation, partnership, or other business entity: TA Operating, LLC 24601 Center Ridge Road Suite 200 Westlake, OH 44145 Contact: Katie Wells 440/808-3296 | - name and address where tanks are located: Petro Stopping Center 24225 W.Lorenzo Road Wilmington, IL 60481 Will County Contact: Lucy Shields 770/367-8179 |

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|---------------|----------------|-----------------|--------------------|-------------------------|
| 7 | B-99 | 20,000 | Tank Not Installed | Federal |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|---------------|
| Corrosion Protection - Piping | Fiberglass Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Fiberglass Double Wall Ameron Dualoy 3000/LCX | New |
| Piping | Fiberglass Single Wall Piping Ameron 4000 L single wall vent | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Double Wall Owens Corning | New |

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions.

There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

Installation of 20,000 gallon B-99 underground storage tank and separations by design bio blending syste, and tieing into existing piping.

Special Contingencies

NOTES: Vent must meet section 175.440 of our rules. For a localized drawing of the tank, piping and blending shed please see page F-2 of the packet included with the permit application.

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|--|
| Northern Indiana Mechanical 3311 East 15th avenue Gary, IN 46403 | Contact Person: Madeline Kingery Phone: 219/963-1640 Email: nimco653@hotmail.com Contractor License # IL292 Exp. 5/8/2025 |

Sincerely,



Daniel Starks