



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2026365  
Permit #: 01052-2025UPG  
Request Rec'd: 08/12/2025  
Approval Date: 08/12/2025 DS  
Permit Expires: 02/13/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Mt. Prospect Park District 1000 W. Central Road Mount Prospect, IL 60056 Cook County Contact: Greg Kuhs 847/255-5380	<b>FACILITY</b> - name and address where tanks are located: Mt. Prospect Park District 600 See Gwen Mount Prospect, IL 60056 Cook County Contact: Mathew Dziubinski 847/632-9330
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	1,000	Currently in use	Federal
7	Diesel Fuel	1,000	Currently in use	Federal

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging OPW ProGauge MagLink LX Plus	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging OPW ProGauge MagLink LX Plus	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

**Summary of Work**

Beacon SSI, Inc. will replace the current OPW ATG with an OPW ProGauge MagLink ATG. All interstitial sensors and in-tank probes will remain.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154	Contact Person: Patrick Ferriter Phone: 708/917-2263 Email: patrick.ferriter@beaconssi.com Contractor License # IL002336 Exp. 1/27/2027

Sincerely,

*Daniel J. Starks*

Daniel Starks