



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2023098
Permit #: 00806-2025UPG
Request Rec'd: 06/29/2025
Approval Date: 06/30/2025 DS
Amended Date: 08/13/2025 DS
Permit Expires: 12/30/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: M & Y Dolton Property, LLC 1421 E. Sibley Blvd. Dolton, IL 60419 Cook County Contact: Mohamed Ali 708/983-9620	FACILITY - name and address where tanks are located: Hala Dolton d/b/a Exxon 1421 E. Sibley Blvd. Dolton, IL 60419 Cook County Contact: Mohamed Alli 708/983-9620
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping A.O. Smith	New
Piping	Shear Valves	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping A.O. Smith	New
Piping	Shear Valves	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping A.O. Smith	New
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
9/10	Sump / Sensors Changing

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing

Summary of Work

Replacing dispenser sump at disp 9/10 with new Bravo FG SW dispenser sump, repiping again, new shear valves, existing sump sensor.


Special Contingencies

Amendment Reason:

We are not replacing submersible pump, ball valve and flexhose on Regular North tank. so we want to remove it from permit. adding 3' of ameron sw fibreglass piping that we used for dispenser sump installation on 9/10

PERSON, FIRM OR COMPANY PERFORMING WORK:	
American Petroleum Solutions LLC 2911 Lund avenue apt 8 Rockford, IL 61109	Contact Person: Haibat Khan Phone: 909/312-9449 Email: apetro.office@gmail.com Contractor License # IL002454 Exp. 5/21/2026

Sincerely,



Daniel Starks