



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 6017243  
Permit #: 00881-2025UPG  
Request Rec'd: 07/10/2025  
Approval Date: 07/11/2025 DS  
Amended Date: 08/13/2025 DS  
Permit Expires: 01/13/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Alka Patel 904 Spyglass Hill Court Caseyville, IL 622322825 St. Clair County Contact: Alka Patel 618/558-6425	<b>FACILITY</b> - name and address where tanks are located: Fairview BP, Inc. 10040 Lincoln Trail Fairview Heights, IL 62208 St. Clair County Contact: Alka Patel 618/558-6425
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	10,000	Currently in use	Federal
5	Gasoline - Premium	10,000	Currently in use	Federal
6	Diesel Fuel	10,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump West	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Flexible Double Wall
Piping	Single Wall STP/Tanktop Sump	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump West	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech P150SC
Piping	Single Wall STP/Tanktop Sump	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump West	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Flexible Double Wall
Piping	Single Wall STP/Tanktop Sump	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Dispensers on the Permit**

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9/10	Sump / Sensors Changing
11/12	Sump / Sensors Changing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser 5/6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser 7/8 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser 9/10 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser 11/12 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Summary of Work**

There are three tanks at this site and each tank has two sumps listed (East and West sumps) The West sumps for each tank is the STP sump and has existing sump sensors with positive shut down. The East sumps contain the spill bucket, tank probe riser and vapor valve/vent extractor. We intend to remove the East sump from each tank and pipe the Spill bucket , tank probe riser and vapor valve to grade level. The permit app is requiring a sump sensor for the East Sump on tank #4 and #5 but these will not be installed since we are removing the East sumps. We are replacing the existing product piping with APT XP 150SC. The pipe will be pulled into the existing sumps through the existing chase pipe. The existing piping will be removed by pulling out of the chase pipe. This work will be covered under a separate piping removal permit.

**Special Contingencies****Amendment Reason:**


The Premium product line was damaged during construction. Owner has decided to replace all the product lines.

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

UPC Enterprises, LC d/b/a United Petroleum Service  
128 Millwell Drive  
Maryland Heights, MO 63043

Contact Person: Terry Smith  
Phone: 314/241-3767  
Email: terrys@unitedpetro.com  
Contractor License # IL002402 Exp. 2/10/2026

Sincerely,



Daniel Starks

**For Office Use Only****Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

**Dispenser 5/6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

**Dispenser 9/10 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

**Dispenser 11/12 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing