



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2010105  
Permit #: 01055-2025UPG  
Request Rec'd: 08/14/2025  
Approval Date: 08/14/2025 SK  
Permit Expires: 02/17/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: N Jaravelil Petroleum, Inc. 4411 W. Diversey Ave. Chicago, IL 60639 (None) County Contact: Cyriac Philip 773/343-8677	<b>FACILITY</b> - name and address where tanks are located: Citgo 4411 West Diversey Avenue Chicago, IL 60639 Cook County Contact: Omar Ahmed 773/343-8677
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

The RUL Spill bucket failed tri annual testing so replacing it

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2027

Sincerely,

Sean Keane