



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 1011918  
Permit #: 01061-2025UPG  
Request Rec'd: 08/14/2025  
Approval Date: 08/14/2025 DS  
Permit Expires: 02/17/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Beck Oil Company of Illinois 850 E. Thompson St. Princeton, IL 61356 Bureau County Contact: Gerri Frank 815/315-0265	<b>FACILITY</b> - name and address where tanks are located: Beck Oil Company 703 Shooting Park Road Peru, IL 61354 LaSalle County Contact: Ray Wallin 815/224-1076
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Ultra Low Sulfur Diesel	12,000	Currently in use	Federal
5	Gasoline - Premium	12,000	Currently in use	Federal
6	Gasoline - Regular	20,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

Replacing existing Emoc 15 gallon spills with new 5 gallon double walled spills and installing new EBW overfills in place of the OPW overfills in there now.

**Special Contingencies**

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Pipeco, Inc.  
610 29th Street  
Bettendorf, IA 52722

Contact Person: Robert Schafer  
Phone: 563/344-0700  
Email: rob@pipecoinc.com  
Contractor License # IL2034 Exp. 9/28/2026

Sincerely,



---

Daniel Starks