

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 3007186
Permit #: 00931-2025UPG
Request Rec'd: 07/20/2025
Approval Date: 07/21/2025 DS
Amended Date:08/18/2025 DS
Permit Expires: 01/21/2026

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Haj Properties, LLC 2412 N. Sheridan Rd. Peoria, IL 61604 (None) County

Contact: Wafa Haj 772/349-4426

**FACILITY** 

- name and address where tanks are located:

Haj Properties, LLC 2412 North Sheridan Road Peoria, IL 61604

Peoria County

Contact: Wafa Haj 772/349-4426

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	12,000	Currently in use	Federal
7	Gasoline - Premium	12,000	Currently in use	Federal
8	Diesel Fuel	8,000	Currently in use	Federal
9	Kerosene	4,000	Currently in use	Federal

### **Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML

## **Tank 7 Equipment**

<b>Equipment Type</b>	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

#### **Tank 8 Equipment**

<b>Equipment Type</b>	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML

# **Tank 9 Equipment**

<b>Equipment Type</b>	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML

## **Summary of Work**

knocking down balls in tanks from all ball floats and installing overfill droptubes on all 4 tanks. Installing new Double wall spill bucket on premium tank.

# **Special Contingencies**

# **Amendment Reason:**

Adding replacement of premium spill bucket in the permit

### PERSON, FIRM OR COMPANY PERFORMING WORK:

American Petroleum Solutions LLC 2911 Lund avenue apt 8 Rockford, IL 61109

Daniel J. Starke

Contact Person: Haibat Khan Phone: 909/312-9449

Email: apetro.office@gmail.com

Contractor License # IL002454 Exp. 5/21/2026

Sincerely,

Daniel Starks