

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 7011747
Permit #: 01084-2025UPG
Request Rec'd: 08/19/2025
Approval Date:08/19/2025 DS
Permit Expires: 02/19/2026

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

2 James, LLC 5850 Hwy 145 Harrisburg, IL 62946 Saline County

Contact: Mike Duncan 618/694-9060

**FACILITY** 

- name and address where tanks are located:

Mitchellville Country Store 5850 Highway 145 South Harrisburg, IL 62946 Saline County

Contact: Mike Duncan 618/252-6414

#### Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Diesel Fuel	8,000	Currently in use	Federal
7	Gasoline - Premium	4,000	Currently in use	Federal

#### **Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

#### **Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

# **Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

#### **Summary of Work**

Replacing shear valves and flexes on 1&2,3&4,5&6 and sattelite 6. site is scheduling a line test for tanks 5,6 & 7 when completed. Larry S Russell is completing work.

#### **Special Contingencies**

NOTE: UDCs must be installed if not already existing

# PERSON, FIRM OR COMPANY PERFORMING WORK:

JF Acquisition, LLC d/b/a Jones & Frank 100 Perimeter Park Drive Suite H Morrisville, NC 275609203

Daniel J. Starke

Contact Person: Kevin Whritenour

Phone: 618/306-5098

Email: scot.russell@jfpetrogroup.com Contractor License # IL002422 Exp. 5/14/2026

Sincerely,

Daniel Starks