



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2026853
Permit #: 01100-2025REM
Request Rec'd: 08/21/2025
Approval Date: 08/21/2025 DS
Permit Expires: 02/23/2026

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: FEMA 5 NW 0408500 500 C St. South West Washington, DC 20472 Contact: ManuelCenteno 202/646-2872	FACILITY - name and address where tanks are located: WLS Radio Transmitter Site 18301 White Eagle Drive Tinley Park, IL 60487 Cook County Contact: Tim Wright 312/984-5328
--	---

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
3	5,000	Diesel Fuel	
4	6,000	Diesel Fuel	

Summary of Work

- ? Remove the residual fuel from the USTs and piping;
- ? Break and remove the concrete over the USTs;
- ? Excavate and stockpile the soil/stone above and surrounding the USTs to allow removal;
- ? Clean tank under supplied air and witness from the Illinois State Fire Marshal;
- ? Haul tanks off site and supply owner with a certificate of destruction;
- ? Remove and dispose of the interior piping associated with the USTs;
- ? Sample the soil to verify no contamination is present. This sampling activity will be performed in accordance IL-OSFM regulations, 41 Ill. Adm. Code Part 176, and Illinois' Leaking Underground Storage Tank (LUST) program regulations, 35 Ill. Adm. Code Part 734;
- ? Backfill the excavations with stockpiled soil/stone and imported clean fill to grade.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
K Plus Mechanical 10220 Bode St. Unit A Plainfield, IL 605851632	Contact Person: Tim Smith Phone: 815/216-7715 Email: tsmith@kplusmechanical.com Contractor License # IL002455 Exp. 10/26/2026

Sincerely,

Daniel J. Starks

Daniel Starks