



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2019784
Permit #: 01119-2025UPG
Request Rec'd: 08/26/2025
Approval Date: 08/26/2025 DS
Permit Expires: 02/26/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: RDK Ventures, LLC 1120 W. Warner Rd. Tempe, AZ 85284 (None) County Contact: Michele Alvarado 773/456-5280	FACILITY - name and address where tanks are located: Circle K #6806 848 Northwest Highway Fox River Grove, IL 60021 McHenry County Contact: Susan Palmer 812/379-9227
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
13	Gasoline - Regular	12,000	Currently in use	Federal

Tank 13 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

Summary of Work

TANK # 13 REGULAR : Anderson needs to remove the STP, electrical out of the one sump in order for a crack on top of the tank by the probe riser to be repaired. We are not replacing any pipe or the flex connector, just removing / re-installing in order for the repair to be made.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: Keith@Andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel Starks