



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 7012533  
Permit #: 01127-2025ABN  
Request Rec'd: 08/27/2025  
Approval Date: 08/27/2025 DS  
Permit Expires: 02/27/2026

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Union County Hospital District 517 N. Main Street Anna, IL 62906 (None) County Contact: Pete Barger 618/614-0623	<b>FACILITY</b> - name and address where tanks are located: Union County Hospital 517 North Main Street Anna, IL 62906 Union County Contact: Kris Landis 618/833-4511Ext.4217
--	---

**Tanks on the Permit For Piping Only**

\* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
5	2,000	Diesel Fuel	Piping Capped Off

**Explanation of Waiver for Abandonment**

Abandonment of piping because it runs beneath active electrical transformer box and into onsite building.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
RCRA, Inc. d/b/a Earth Services 10903 Prestwick Drive Benton, IL 62812	Contact Person: Josh Appleton Phone: 618/218-4958 Email: earthservices@earthservices.us Contractor License # IL002364 Exp. 8/7/2027

Sincerely,

Daniel Starks