



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047932
Permit #: 01129-2025ABN
Request Rec'd: 08/27/2025
Approval Date: 08/27/2025 SK
Permit Expires: 02/27/2026

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Reach For The Stars Day Care Center, Inc. 6447-6455 S Martin Luther King Drive Chicago, IL 60637 Contact: Lisa Collins 773/877-9413	FACILITY - name and address where tanks are located: Day Care 6447-6455 S Martin Luther King Drive Chicago, IL 60637 Cook County Contact: Lisa Collins 773/877-9413
--	--

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	1,000	Heating Oil	Inert material mixed with portland cement
2	1,000	Heating Oil	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

There are two (2) 2000 Gallon Underground Storage Tanks (UST) 4' diameter * 18' Long Both tanks are 10 feet under load bearing wall. See attached pics

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Chicago Environmental, Inc. 2333 Wisconsin Avenue Downers Grove, IL 605154022	Contact Person: David Streich Phone: 630/776-0024 Email: david@chicagotankremoval.com Contractor License # IL002444 Exp. 4/6/2026

Sincerely,

Sean Keane