



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

FOR OFFICE USE ONLY	
Facility #:	6042984
Permit #:	01041-2025UPG
Request Rec'd:	08/11/2025
Approval Date:	08/11/2025 DS
Amended Date:	08/28/2025 DS
Permit Expires:	02/11/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909 Knox County Contact: Joey Cupp 865/588-7488	<b>FACILITY</b> - name and address where tanks are located: Flying J Travel Plaza #642 140 Racehorse Drive Alorton, IL 62207 St. Clair County Contact: Gregory Jantz 865/588-7488
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	20,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Summary of Work**

CONVERTING REGULAR TANK TO E15 TANK  
amendment -

we are changing the stp motor which will break piping, we are not changing the stp sump, as previously stated

**Special Contingencies**

**Amendment Reason:**

we are not changing the stp sump we are changing the stp motor. need to amend

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026

Sincerely,

Daniel Starks