



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Extended**

**FOR OFFICE USE ONLY**  
Facility #: 2039572  
Permit #: 00251-2025UPG  
Request Rec'd: 03/04/2025  
Approval Date: 03/04/2025 DS  
Extension Date: 08/28/2025  
Permit Expires: 03/04/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.**

|  |   |
|--|---|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Meijer Great Lakes Limited Partnership<br>2929 Walker Avenue, NW<br>Grand Rapids, MI 495449428<br>Contact: Erik Petrovoskis 616/735-7101 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Meijer Gas & C Store #182<br>865 S. Randall Road<br>St. Charles, IL 60174<br>Kane County<br>Contact: Express Team Lead 630/762-7229 |
|--|---|

**Tanks on the Permit**

| Tank # | Product                 | Capacity | Tank Status      | Regulated Status |
|--------|-------------------------|----------|------------------|------------------|
| 4      | Ultra Low Sulfur Diesel | 3,000    | Currently in use | Federal          |

**Tank 4 Equipment**

| Equipment Type          | Permit Equipment                           | Action   |
|-------------------------|--|--|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - European with No Test Req Suction |
| Piping                  | Other Submersible Pump                     | New  |

**Summary of Work**

Converting Kerosene Suction System to Pressurized System  
Replacing Suction Pump with a Dispenser

**Special Contingencies**

| <b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>                 |   |
|---|---|
| R. W. Mercer Company<br>2322 Brooklyn Road<br>Jackson, MI 49203 | Contact Person: Tracy Saylor<br>Phone: 517/206-1946<br>Email: dean@rwmercer.com<br>Contractor License # IL002211 Exp. 6/21/2025 |

Sincerely,

Daniel Starks