

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov **Extended**  FOR OFFICE USE ONLY

Facility #: 2038450
Permit #: 00252-2025UPG
Request Rec'd: 03/04/2025
Approval Date:03/04/2025 DS
Extension Date: 08/28/2025
Permit Expires: 03/04/2026

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

#### **OWNER OF TANKS**

- Corporation, partnership, or other business entity: Meijer Great Lakes Limited Partnership 2929 Walker Avenue, NW Grand Rapids, MI 495449428

Contact: Erik Petrovoskis 616/735-7101

#### **FACILITY**

- name and address where tanks are located:

Meijer Gas Station #169 195 Weber Rd. Bolingbrook, IL 605500951 Will County

Contact: Express Team Lead 630/679-6529

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Ultra Low Sulfur Diesel	3,000	Currently in use	Federal

### Tank 3 Equipment

<b>Equipment Type</b>	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - European with No Test Req Suction
Piping	Other Submersible Pump	New

#### **Summary of Work**

Converting Kerosene Suction System to Pressurized System Replacing Suction Pump with a Dispenser

## **Special Contingencies**

Janiel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
R. W. Mercer Company 2322 Brooklyn Road Jackson, MI 49203	Contact Person: Tracy Saylor Phone: 517/206-1946 Email: dean@rwmercer.com Contractor License # IL002211 Exp. 6/21/2025			

Sincerely,

**Daniel Starks**