



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2028828  
Permit #: 01151-2025UPG  
Request Rec'd: 09/02/2025  
Approval Date: 09/03/2025 DS  
Permit Expires: 03/04/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|   |  |
|---|--|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Thorntons, LLC<br>2600 James Thornton Way<br>Louisville, KY 40245<br>Contact: Maggie Sebaugh 502/572-1259 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Thornton Oil #114<br>180 East Rollins Road<br>Round Lake Beach, IL 60073<br>Lake County<br>Contact: Wayne Hoffman 847/740-8021 |
|---|--|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1      | Gasoline - Regular | 12,000   | Currently in use | Federal          |
| 2      | Gasoline - Regular | 12,000   | Currently in use | Federal          |
| 3      | Gasoline - Premium | 12,000   | Currently in use | Federal          |
| 4      | Diesel Fuel        | 6,000    | Currently in use | Federal          |
| 5      | Diesel Fuel        | 6,000    | Currently in use | Federal          |
| 6      | E85                | 12,000   | Currently in use | Federal          |

**Tank 1 Equipment**

| Equipment Type          | Permit Equipment  | Action  |
|-------------------------|---|---|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection                | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection         |
| Leak Detection - Tank   | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

**Tank 2 Equipment**

| Equipment Type          | Permit Equipment  | Action  |
|-------------------------|---|---|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection                | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection         |
| Leak Detection - Tank   | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

### Tank 3 Equipment

| Equipment Type          | Permit Equipment  | Action  |
|-------------------------|---|---|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection                | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection         |
| Leak Detection - Tank   | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

### Tank 4 Equipment

| Equipment Type          | Permit Equipment  | Action  |
|-------------------------|---|---|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection                | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection         |
| Leak Detection - Tank   | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

### Tank 6 Equipment

| Equipment Type          | Permit Equipment  | Action  |
|-------------------------|---|---|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection                | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection         |
| Leak Detection - Tank   | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

### Summary of Work

Remove existing TLS350 & Install TLS450+ w/CSLD. Replace existing EPLLD w/New

### Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK:                                       |   |
|--|---|
| Stenstrom Petroleum Services Group<br>2422 Center Street<br>Rockford, IL 61108 | Contact Person: Robert Stenstrom<br>Phone: 815/398-6250<br>Email: amberp@rstenstrom.com<br>Contractor License # IL1890 Exp. 4/12/2026 |

Sincerely,



Daniel Starks