



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2007979
Permit #: 01168-2025UPG
Request Rec'd: 09/04/2025
Approval Date: 09/04/2025 DS
Permit Expires: 03/04/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: I-55 Truckstop Properties LLC 510 S. Bolingbrook Drive Bolingbrook, IL 60440 Will County Contact: Robin Puthusseril 847/942-9535	FACILITY - name and address where tanks are located: Greater Chicago Truck Plaza 510 South Bolingbrook Drive Bolingbrook, IL 60440 Will County Contact: Jeremy Smith 630/739-7006
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
13	Diesel Fuel	20,000	Currently in use	Federal
14	Diesel Fuel	20,000	Currently in use	Federal

Tank 13 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New

Tank 14 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New

Summary of Work

We will be adding a siphon system for the two diesel tanks. Saw cut one 5' x 20' area for a trench between the tanks for the siphon line. Demolition of concrete and disposal. Hydro excavate between the tanks to the tank top. Stockpile pea gravel onsite to be reused. Provide and install two (2) OPW extractor fittings with suction drops and risers. Provide and install Ameron fiberglass between the tanks. Provide and install red jacket functional elements, check valve and siphon tube. Provide and install copper tubing from the existing submersible to the siphon line high point. Hydrostatic test tank sump with suction line. Perform primary and secondary line testing. Perform tank tests to include new siphon line. Back fill using pea gravel. Dowel and pin the trench. Provide two (2) OPW 18" manholes for siphon risers. Pour concrete and finish.

Special Contingencies

NOTES: Sump sensors with positive shut down must be installed in both tank sumps if not already existing. Violations for tank 16 must be complied at the time of this permitted work.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Northern Indiana Mechanical 3311 East 15th avenue Gary, IN 46403	Contact Person: Madeline Kingery Phone: 219/963-1640 Email: nimco653@hotmail.com Contractor License # IL292 Exp. 5/9/2027

Sincerely,

Daniel J. Starks

Daniel Starks